
RE: 263 West Main Street

From: "Chief Dean Kochanowski" <dudleyfirechief@dudleyma.gov>

Date: 06/02/2020 01:28PM

To: <planner@dudleyma.gov>

The only thing we would require is that any fire roads and access roads need to be a width of 20ft. minimum per NFPA 1. We need access for apparatus to access all 4 sides of the lot in case of fire. Thanks

Chief Dean Kochanowski
Fire Chief/EMD
128 West Main Street
Dudley, Ma 01571>
PH: 508-949-8040 Ext. 225
Fax: 508-943-4424
Cell: 774-318-0176

cid:imag
e001.jpg
@01D3B
9F3.E9D

From: planner@dudleyma.gov [mailto:planner@dudleyma.gov]

Sent: Wednesday, May 27, 2020 10:18 AM

To: Dudley Fire Chief

Subject: 263 West Main Street

Hi Chief:

We have the continuation of the public hearing tonight for the 500-space parking lot at 263 West Main Street (the Enterprise/driving range site). I haven't heard from you and wondered if you had any comments from a fire safety perspective. I'm attaching the site plan. I have a large scale set in the Planning office.

I think the main thing would be keeping fire lanes clear and ensuring your vehicles could get in and out of the site. Any suggestions for cleaning up the site for fire safety purposes would be welcome. If you have no comments, that's fine too, just let me know.

Thanks.

Bill

Attachments (1 file, 3.9 KB)